

### **ADDENDUM #3 –ANSWERS TO PROPOSER QUESTIONS**

1. What is the existing meter brand? **Badger, Master, Neptune, Rockwell**
2. What is the approximate geographic area of the meters to be covered under this contract? **60 square miles**
3. Who takes possession of the old meters and registers? **Village of Forest Hill**
4. What is the Billing Software the city/county is utilizing? **Munilink**
5. If the collection of GPS points is required, is 1–5-meter accuracy acceptable? (Requested clarification)
6. Who will be providing the warehousing for all materials? **Village of Forest Hill**
7. Will the prime contractor be paid for “stored materials”? **No**
8. How are meters currently being read? **Manually**
9. What is the material of the existing lids? **Concrete & plastic**
10. Are there any existing holes in the lid? **No**
11. What percentage of meter boxes is located in concrete or asphalt? **None**
12. What is the composition of meter box? (material) **Concrete & plastic**
13. What is the size of meter boxes? **Regular & jumbo**
14. Do all settings have shut off valves before the meters? **Yes**
15. Are all valves in the meter box? **Yes**
16. What is the procedure for any inoperable or broken valves? **Replace**
17. Will we be installing any additional product, i.e. broken stop valves, dual check valves? **Yes**
18. What is the average meter depth? **6-12 inches**
19. What is the age and primary make-up of service lines? (Copper, plastic galvanized) **50 years, PVC & CTS**
20. Are the meters in setters, or are they connected with straight meter couplings? **Both**